


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 09147 / 01.12.2009**

NUMBER	09147	DATE	01 / 12 / 2009
---------------	--------------	-------------	-----------------------


Client' s data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE
Product description:	SINGLE SASH WINDOW WITH ONE FIXED ELEMENT TILT / TURN
Material:	ALUMINIUM
System :	E – 40 Thermo



1410 x 2215mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class E750
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C3

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOPI PAPAPOPOULOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL