


## SUMMARY OF RESULTS OF TESTING CERTIFICATE 0537 / 04.07.2005

<b>NUMBER</b>	0537	<b>DATE</b>	04 / 07 / 2005
---------------	------	-------------	----------------

<b>Client' s data:</b>	<b>ETEM S.A.</b> LIGHT METALS COMPANY 1, IROON POLYTEHNIUO STR. GR 190 18 MAGOULA ATTIKIS - GREECE
<b>Product description:</b>	<b>DOUBLE SASH WINDOW SLIDING</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>E - 19</b>



1310 x 1310 mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 3</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 4A</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C4</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPADOPOULOU**  
TECHNICAL MANAGER



**IOANNIS GKERTSOS**  
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL