


**SUMMARY OF RESULTS  
OF TESTING CERTIFICATE 1004 / 04.02.2010**

<b>NUMBER</b>	<b>1004</b>	<b>DATE</b>	<b>04 / 02 / 2010</b>
---------------	-------------	-------------	-----------------------

<b>Client' s data:</b>	<b>ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE</b>
<b>Product description:</b>	<b>SLIDING POCKET TWO LEAF BALCONY DOOR</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>E - 22</b>



<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 3</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 3A</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C3</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPAPOULOU  
TECHNICAL MANAGER**



**IOANNIS GKERTSOS  
GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL