


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 10103 / 13.10.2010**

NUMBER	10103	DATE	13 / 10 / 2010
---------------	--------------	-------------	-----------------------

Client' s data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIUOY STR. GR 196 00 MAGOULA ATTIKIS - GREECE
Product description:	SINGLE SASH BALCONY DOOR TILT / TURN
Material:	ALUMINIUM
System :	E – 2300



1050 x 2210mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class E 1050
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C3

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOI PAPADOPOULOU
LABORATORY MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL