



**IRCCOS** S.c.a r.l.

*Istituto di Ricerca e certificazione per le Costruzioni Sostenibili*

Test Laboratory Notified in accordance with Regulation (EU) No 305/2011

## TEST REPORT

*Number:*

**1994-CPR-RP1051**

*Issuing date:*

**2014-05-26**

*Applicant:*

**Etem SA**

**Iroon Polytechniou str, 1  
1908 – Magoula, Attiki (Greece)**

*Tested product:*

**Single vent door  
Trade name: "E-38"  
(cf. description)**

*Executed tests:*

**Air permeability  
Watertightness  
Resistance to wind load**

*Normative References:*


**EN 14351-1:2006+A1:2010  
EN 1026:2000      EN 12207:1999  
EN 1027:2000      EN 12208:1999  
EN 12211:2000     EN 12210:1999**

*The report is done up of 21 pages, including any annex, and can be reproduced only integrally.*

*Sede legale Via Cremona 1 - 20025 Legnano (MI) - Tel. 0331 594628 - Fax 0331 458211 - [www.irccos.com](http://www.irccos.com)  
Cap. Soc. € 111.526 I.V. - C.F. e P. Iva 05159630960 - Reg. Imprese Milano 05159630960 - R.E.A. 1799766*

*Società partecipata a maggioranza dal Consiglio Nazionale delle Ricerche*

**9 Resume of classes assigned on the basis of the results of the tested sample of a Single vent door with trade name “E-38”, according to TR n° 1994-CPR-RP1051, issued on 2014-05-26 to ETEM SA.**

Scheme of the tested sample	Test	Test standard	Classification standard	Obtained Class	Cf. § TR
	Air permeability	EN 1026:2000	EN 12207:1999	class 4	§ 7.2.1
	Watertightness	EN 1027:2000	EN 12208:1999	class E750	§ 7.3.1
	Resistance to wind load	EN 12211:2000	EN 12210:1999	class C4	§ 7.4.5


**10 Limitations**

This Test Report does not represent either an evaluation the suitability of use or a certificate of product conformity. The results obtained refer exclusively to the samples tested.

**Technical Operator**  
Katia Foti



**The chairman**  
for Dott. Italo Meroni



-----End of the Test Report No. 1994-CPR-RP1051-----