



IRCCOS S.c.a r.l.

Istituto di Ricerca e certificazione per le Costruzioni Sostenibili

Test Laboratory Notified in accordance with Directive 89/106/CEE No. 1994

TEST REPORT

Number:

1994-CPD-RP0816

Issuing date:

2012-06-29

Applicant:

Etem SA

**Ironon Polytechniou str, 1
1908 – Magoula, Attiki (Greece)**

Tested product:

**Single vent TT window of E75 series tilt & turn
Trade name: "E75_SINGLE VENT TT WINDOW"
(cf. description)**

Executed tests:

**Air permeability
Watertightness
Resistance to wind load**

Normative References:

**EN 14351-1:2006+A1:2010
EN 1026:2000 EN 12207:1999
EN 1027:2000 EN 12208:1999
EN 12211:2000 EN 12210:1999**

The report is done up of 23 pages, including any annex, and can be reproduced only integrally.



9 Resume of classes assigned on the basis of the results of the tested sample of single vent tt window of E75 series tilt & turn with trade name “E75_SINGLE VENT TT WINDOW”, according to TR n° 1994-CPD-RP0816, issued on 2012-06-29 to ETEM SA.

Scheme of the tested sample	Test	Test standard	Classification standard	Obtained Class	Cf. § TR
	Air permeability	EN 1026:2000	EN 12207:1999	class 4	§ 7.2.1
	Watertightness	EN 1027:2000	EN 12208:1999	class E900	§ 7.3.1
	Resistance to wind load	EN 12211:2000	EN 12210:1999	class C5	§ 7.4.5

10 Limitations

This Test Report does not represent either an evaluation the suitability of use or a certificate of product conformity. The results obtained refer exclusively to the samples tested.

Technical Operator

Elisa Farioli

The chairman

for Dott. Italo Meroni

-----End of the Test Report No. 1994-CPD-RP0816-----